



WellKey: 9DU

General Information

Owner Name (log): Richard Lee Hoskins

DOE Tag: AGA655

DOE NOI:

DOE ID

797410

Well Address: 810' West 600' north of SE corner of

Well Parcel: **R23007-330-1370**

Served Parcel:

Horiz/Vert Accuracy: Site Plan / Survey

Site Type: Well

USGS ID: [480612122354501](#)

SWI Rating: Very-High Risk



Construction Information

Construction Date: 06/15/74

Driller Name: B & W Drilling Co.


LS Elevation: 141.04 ft. MSL

Depth Well: 185 ft.

TD Elevation: -44 ft. MSL

WL Measurements: [4 measurements \(Click to View\)](#)

WL Elevation: 4.54 ft. MSL



Water Quality Information

Water Samples: [12 samples \(Click to View\)](#)


Avg/Med/Max Arsenic: 0.002 / 0.002 / 0.002 mg/l

Avg/Med/Max Chloride: 18.00 / 18 / 20 mg/l

Avg/Med/Max Hardness: 93.30 / 93.3 / 93.3 mg/l

Avg/Med/Max Nitrate: 5.64 / 5.7 / 6.7 mg/l

Bacteria Sampls (distribution): [24 samples \(Click to View\)](#)



Public Water System Information

Pws Name: Eaglebluff Property Owners Assn

PwsID: **53171**

Approved Connects: 7

Pws Source #: SO# 1

Pws Source Name: Well #1 AGA655

Note: Underlined items in bright blue are hyperlinks to additional information / resources.

Questions? Contact the [Island County Hydrogeologist](#), or visit the [Hydrogeology Web Page](#).

Report Generated: 12/30/2020

